

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

LISTING No. 3295-1454:103 Page 1 of 1

CATEGORY: Fire-Rated Door

LISTEE: American Door Manufacturing, 1488 Tillie Lewis Dr., Stockton, CA 95206  
Contact: Randy Neto (209) 941-8852

DESIGN: Door, single, pairs, or double egress swinging flush type, mineral core fire door.

Core: three pieces proprietary composite mineral core 1-1/2"x 81-3/4"x 34-3/16", 1-1/2"x 81-3/3"x12', 1-1/2"x 11-1/8'x 46-7/32."

Top Rail and Stiles: 1-1/2" x 1" fire retardant treated fir.

Bottom Rail: two pieces of 1-1/2" x 1" treated fir.

Skins: 1/8" three ply birch plywood, Type II per NWMA Standard IS-1.

Adhesive: Borden Chemical WB-904 adhesive plus M-150-L Catalyst or approved equivalent adhesive.

Press Conditions: Cold pressed.

Maximum size not to exceed 4' wide x 10' high for single and 8'wide x 8' high for pairs and double egress. Metal edges with astragal required on pairs and double egress. Lites not to exceed 100 in<sup>2</sup>.

RATING: 60 Minutes

INSTALLATION: In accordance with listee's printed installation instructions, ANSI/NFPA 80, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, rating/classification, CSFM and EEL labels.

APPROVAL: Listed as 60 minutes fire door assembly when installed in a listed frame approved for the type of wall construction.

04-29-97



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy  
Program Manager**